



Government of West Bengal  
Office of the Divisional Fire Officer  
West Bengal Fire & Emergency Services  
Jalpaiguri Fire Station, Race Course Para, P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo No.: FSR/IND/WB/FES/20192020/51896

Date : 20-06-2024

From :  
Divisional Fire Officer  
Jalpaiguri Division,  
West Bengal Fire & Emergency Services

To :  
D.A.V. School  
Mouza: Binnaguri, Plot No.: 124(P), 125(P), 126, 127, 125/392, 281, 282, 284, Vill.: Jogivita, Fulbari, P.O.: Mahananda Barrage, Dist.: Jalpaiguri, Pin.: 734015.

Sub : Issuance of Renewal of Fire Safety Certificate for the G+2 School Building under group of educational name D.A.V. School, Mouza-Binnaguri, Plot No-124(P), 125(P), 126, 127, 125/392, 281, 282, 284, Vill- Jogivita, Fulbari, P.O.- Mahannanda Barrage, Dist- jalpaiguri, Pin-734015.

This is in reference to your AIN 211912406300000802 dated 05-Jun-2024 regarding Issuance of Renewal of Fire Safety Certificate for the G+2 School Building under group of educational name D.A.V. School, Mouza-Binnaguri, Plot No-124(P), 125(P), 126, 127, 125/392, 281, 282, 284, Vill- Jogivita, Fulbari, P.O.-Mahannanda Barrage, Dist- jalpaiguri, Pin-734015..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

**Recommendation:**

Subject to fulfillment following condition:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliance, No parking board will be allowing on the driveway.



ATTESTED

*Tapash Pal Sank*  
12/06/24  
PRINCIPAL  
D.A.V. SCHOOL, SILIGUR

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000802

2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will be strictly maintaining.
  3. Arrangements shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building by a License agency and to keep those in perfectly good working condition all the times and it should be written in the register.
  4. Adequate number of "NO SMOKING" boards should be displaying surrounding the premises.
  5. Existing electrical wiring and installation of whole building should be carefully checking and maintenance regularly by a licensed electrician for any wear and tear at those, particularly wiring on false ceiling and ducts.
  6. The employees and security staff shall be conversant with installed Firefighting equipment of the building and to operate in the event of Fire and Testing.
  7. Transformer and switchgear room should be protecting with automatic CO2 or D.C.P. Fire Extinguisher conforming I.S. specification.
  8. First Aid Firefighting system should be providing as per I.S. specification
  9. All The Firefighting Extinguisher should be test once in a year.
  10. If required the old Firefighting system should be replaced with new, the cables will be always laying in M.S. conduit pipe continuously bonded to the earth.
  11. The Fire Safety audit to be conduct a regular interval and to be recorded in the Fire Prevention maintenance register.
  12. A crew of trained Fireman under the experienced officer shall be depute and maintained round the clock for safety of the building.
  13. All employees should be trained to operate the Firefighting equipment of the school building, that they can operate the same in case of exigency.
  14. Mock fire drill and evacuation drill should be done periodically with participation of all the Students, personnel and security guards.
  15. A register for the recording of Mock fire drill, evacuation drill ,testing and checking of whole firefighting installation, electrical installation will be maintained & liable to produce the same to the authorized officer of this department on demand.
- This Certificate is valid for 3 years u/r 18 of W.B.F.S. (Fire Prevention and Safety ) Rules, 2003 and renewable after 3 years from the date of issue failing which this shall be revoked automatically.

Valid Upto : 19-Jun-2027

Memo No.:

FSR/IND/WB/FES/20192020/51896

*Tapan Pal*  
12/05/20

- PRINCIPAL  
D.A.V. SCHOOL SILIGURI

ATTESTED



Signature valid

Digitally Signed,  
Name: DEWAN LAL CHA  
Date: 20-Jun-2022 12:49:58  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 21191240630000802